

ಶ್ರೀ ಎಸ್. ಎಂ. ಚಂದ್ರಶೇಖರ್.—'ದೀಪದ ಬುಡ ಕತ್ತರ' ಎನ್ನುವಂತೆ ಲಿಂಗನವಕ್ಕೆ ಜಲಾಶಯದಿಂದ ದೀಪ ಸಂಸ್ಥಾನ ಮತ್ತು ಇತರ ರಾಜ್ಯಗಳಿಗೆ ವಿದ್ಯುಚ್ಛಕ್ತಿ ಹೋಗುತ್ತಿದೆ. ಆದರೆ ಲಿಂಗನಮಕ್ಕಿ ಜಲಾಶಯದ ಹತ್ತಿರ ಹತ್ತಿರ ಇರತಕ್ಕ ಗ್ರಾಮಗಳಿಗೆ ವಿದ್ಯುಚ್ಛಕ್ತಿ ಮಂಜೂರಾಗಿಲ್ಲ ಎನ್ನುವುದು ಮಾನ್ಯ ಮಂತ್ರಿಗಳ ಗಮನಕ್ಕೆ ಬಂದಿದೆಯೇ ?

Sri H. M. CHANNABASAPPA.—There may not be a number of cases where the power has not been sanctioned. The villages round about might not have fulfilled the requirements for electrification. If these villages satisfy the usual norms, we will certainly do the needful. ಗ್ರಾಮಾಂತರ ಜನಗಳಿಗೆ ತಾವು ಏನೇನು ಕಾರ್ಯಕ್ರಮ ತೆಗೆದುಕೊಳ್ಳಬೇಕು, ಅವೆಲ್ಲ ಪೂರೈಕೆಯಾಗಿ ಮತ್ತು ನಮ್ಮ ಇನ್‌ಫ್ರಾ ಸ್ಟ್ರಕ್ಚರ್‌ನಲ್ಲಿ ವಿದ್ಯುಚ್ಛಕ್ತಿಯನ್ನು ಪೂರೈಸುತ್ತೇವೆ.

ಶ್ರೀ ಕೆ. ಎಚ್. ಹನುಮೇಗೌಡ.—ಗವರ್ನರ್ ಕಾಲದಲ್ಲಿ ಎರಡು ಪಟ್ಟಿ ಮಾಡಿದ್ದರು. ಎರಡನೇ ಪಟ್ಟಿಯನ್ನು ತೆಗೆದುಕೊಳ್ಳುವ ಸಂದರ್ಭದಲ್ಲಿ ಎಕಾನಮಿ ಮೆಷ್ಯಾನ್‌ನಿಂದ ಕೆಲಸವನ್ನು ನಿಲ್ಲಿಸಲು ಆದೇಶ ಕೊಟ್ಟಿದ್ದರು. ಎಂಟು ಹತ್ತು ದಿವಸಗಳ ಕೆಳಗೆ ಮಾನ್ಯ ಮಂತ್ರಿಗಳ ಮಾತನಾಡುವಾಗ ಯಾವ ಯಾವ ಕೆಲಸಗಳನ್ನು ಮಿತವ್ಯಯ ದೃಷ್ಟಿಯಿಂದ ನಿಲ್ಲಿಸಲಾಗುತ್ತೋ ಅವುಗಳನ್ನು ಮಾಡುವಂತೆ ಹೇಳಿದ್ದೇವೆಂದು ತಿಳಿಸಿದರು. ಹೀಗಾದಲ್ಲಿ ಈ ಬಗ್ಗೆ ಏನೂ ಡೈರೆಕ್ಷನ್ ಹೋಗಿಲ್ಲ. ಬೇಗ ಆದೇಶ ಕಳುಹಿಸುವ ವ್ಯವಸ್ಥೆ ಮಾಡುತ್ತಾರೆಯೇ ?

ಶ್ರೀ ಎಚ್. ಎಂ. ಚನ್ನಬಸಪ್ಪ.—ಹೋದ ವರ್ಷ ವಿದ್ಯುಚ್ಛಕ್ತಿಯನ್ನು ಕೊಡಲು ಎಷ್ಟು ವೇಗದಲ್ಲಿ ಕೆಲಸ ಮಾಡಿವೆಯೋ ಅದಕ್ಕಿಂತ ಕಡಿಮೆ ಇಲ್ಲದಾಥ ವೇಗವಿಂದ ಕೆಲಸ ಮಾಡಬೇಕೆಂದು ಹುಕುಂ ಕೊಟ್ಟು ಮೂರು ನಾಲ್ಕು ದಿವಸಗಳಾಗಿವೆ. ಅದು ಇನ್ನೂ ಚಾನ್ಸಿಟನಲ್ಲರಬಹುದು ಎಂದು ಕಾಣುತ್ತದೆ.

ಅಧ್ಯಕ್ಷರು.—271, 573 ಮತ್ತು 640 ನೇ ಪ್ರಶ್ನೆಗಳನ್ನು ಒಟ್ಟಿಗೆ ತೆಗೆದುಕೊಳ್ಳೋಣ.

### Damage to Canal of Sharavathy Valley Project

271. Sri KAGODU THIMMAPPA (Sagar).—

Will the Minister for Public Works and Electricity be pleased to state:—

(a) the amount that was spent for canal between Lingannakki dam and Surge tank ;

(b) whether the design for the said canal was obtained from a private firm, if so, the amount paid by the Government for the same ;

(c) the justification of obtaining the design from a private firm when the Government had technical staff with them ;

(d) whether the rumour that the canal is damaged is true ; if so, on whom the responsibility fixed by the Government?

Sri H. M. CHANNABASAPPA (Minister for Public Works).—

(a) The total amount incurred on Water Conductor System from Lingannakki Dam up to the Surge tank in the Sharavathi Valley project is Rs. 3,97,93,271.

(b) The tender accepted for the construction of power channel, which is one of the components of the Water Conductor System, was based on contractor's design and drawings.

(c) On technical advice, a choice was given in the tender for the contractors to furnish their own alternative design and to quote rates for both the departmental as well as their own design.

(d) Yes. Damages were observed in 1963 and 1964 and they were immediately got repaired. The question of locating the causes for these damages as also to fix responsibility for the same is engaging the attention of Government.

### Defects in the Tunnel of Sharavathy Valley Hydro-electric Project

573. Sri C. M. ARUMUGAM (K.G.F.).—

Will the Minister for Public Works and Electricity be pleased to state :—

(a) whether there is any defect in the pressure tunnel of the Sharavathi Valley Hydro-Electric Project ;

(b) if so, whether it has been brought to the notice of the authorities concerned ;

(c) the action taken in that behalf ;

(d) the estimated expenditure to repair the tunnel ;

(e) the names of the contractor, Chief Engineer, Superintending Engineer, Executive Engineer and Assistant Engineers who were in-charge when the tunnel was constructed.?

Sri H. M. CHANNABASAPPA (Minister for Public Works).—

(a) Some damages have been observed in the pressure tunnel No. 1 of the Sharavathy Valley Hydro-Electric Project.

(b) Yes.

(c) The Mysore Power Corporation is seized of the matter and is making arrangements for carrying out repairs during August-September 1972.

(d) The expenditure required for repairs can be assessed only after knowing the extent of the damages caused to the tunnel.

(e) Contractors—M/s. Hindustan Construction Co. List of officers is given below as per information compiled so far.

Chief Engineers :

1. Sri L. C. Muniswamy Reddy.  
(Deceased)
2. Sri Iftikar Ahmed (on leave preparatory to retirement)
3. Sri L. T. Aminbhavi (Retired)